



January 3, 2017

ADDENDUM NO. 1 TO ALL BIDDERS:

Invitation to Bid: ITB#17-02-09A

Description: Trevino Circle / Monterey Road Channel Improvements Project

Dated: December 2, 2016

For Delivery to: Purchasing Division, City of Roanoke, Virginia

Bid Due: January 12, 2017

Guardrail replacement located near the Monterey Road culvert has been removed from the scope of work for the construction of the project. (Sheet C201 of the project drawings)

New guardrails will be installed near the Old Mountain Road culvert. The proposed guardrail at the downstream end of the Old Mountain Road culvert shall compose of a GR-9 terminal and a GR-2. The 50ft GR-9 terminal shall tie to GR-2. The proposed guardrail on the upstream end of the Old Mountain Road culvert shall be GR-2. The GR-2 end section shall be rounded. (Sheet C203 & C204 of the project drawings)

It is preferable during construction of the project that work activities are performed in an upstream direction. However, the contractor has the option to perform work in the downstream direction.

Plantings specified on C201 of the plan drawings shall be installed for this project. No other substitute will be utilized for the specified plantings.

Note: A signed acknowledgment of this addendum should be received at the location indicated on the ITB either prior to the due date and hour or attached to your response. Signature on this addendum does not substitute for your signature on the original bid document. The original bid document must be signed.

Very truly yours,

Monica Cole
Purchasing Supervisor
Phone: 540-853-2871

Name of Firm

Signature/Title

Date